



Kathy Rose <krose@bexley.org>

FW: 471 North Park View fence in floodplain

1 message

David Reutter <DReutter@franklinswcd.org>

Thu, Oct 29, 2020 at 4:32 PM

To: "krose@bexley.org" <krose@bexley.org>, Andy Bashore <ABashore@bexley.org>

Cc: "conveyorguard@aol.com" <conveyorguard@aol.com>

Second try – I got an undeliverable last message.

From: David Reutter **On Behalf Of** FSWCD-DATA**Sent:** Thursday, October 29, 2020 4:20 PM**To:** krose@bexley.org**Cc:** Kylie Davis <KDavis@franklinswcd.org>; Kyle Wilson <KWilson@franklinswcd.org>**Subject:** FW: 471 North Park View fence in floodplain

Kathy – Mr. Furrow is inquiring where this stands and I'm resending my response for your use.

DAVID REUTTER, CESSWI #0419

Urban Conservationist

Franklin Soil and Water Conservation District

[1404 Goodale Blvd. Suite 100, Columbus, OH 43212](https://www.franklinswcd.org/)**o:** 614-486-9613, ext. 127 | **e:** dreutter@franklinswcd.org**Connect with us online!****Developing Lands** | [Be The Change for Clean Water](#)

From: David Reutter**Sent:** Thursday, October 15, 2020 10:55 AM**To:** krose@bexley.org**Subject:** 471 North Park View fence in floodplain

Good Morning Kathy – I spoke with Jim Furrow this morning about the proposed fence in the floodplain and want to relay the information to you as well. Structures are allowed in the floodplain as long as they do not impede flow. This can be done by using open bottoms and break-away type construction that accounts for the base flood elevation (BFE) found on the area NFIP FEMA map for the area. I haven't seen the particulars of this case, but a chain link fence could extend into the floodplain as long as the bottom chord is level with the BFE or would be constructed in a way to allow flow (or debris) to be unimpeded.

If you have any questions feel free to contact me, email is best these days, or you can try my work cell #614-512-2848.

DAVID REUTTER, CESSWI #0419

Urban Conservationist

Franklin Soil and Water Conservation District

[1404 Goodale Blvd. Suite 100, Columbus, OH 43212](#)

o: 614-486-9613, ext. 127 | **e:** dreutter@franklinswcd.org

Connect with us online!



Developing Lands | **Be The Change for Clean Water**