

ORDINANCE NO. 59-06

By: Mr. Lampke

An Ordinance to appropriate \$5,500.00 from the unencumbered General Fund for the purpose of replacing the air conditioning unit which serves the west wing of the first floor of Bexley City Hall and to declare an emergency.

*Whereas*, the air conditioning unit that serves the west wing of the first floor of Bexley City Hall is failing and must be replaced; and,

*Whereas*, it is essential to replace the unit before it fails and causes the City's information systems servers to overheat and fail, necessitating the shut down of the computer system. **NOW, THEREFORE,**

**BE IT ORDAINED BY THE COUNCIL OF THE CITY OF BEXLEY, OHIO:**

Section 1. That the amount of \$5,500.00 should be and hereby is appropriated from the unencumbered General Fund for the purpose of replacing the air conditioning unit which serves the west wing of the first floor of Bexley City Hall.

Section 2. That this Ordinance is an emergency ordinance necessary for the public safety and welfare, the emergency being the need to provide air conditioning to protect the City's computers systems, as well as provide cooling to the Auditor and Water Departments, and shall take effect upon its passage and approval by the Mayor.

Passed: August 2 2006

Helen MacMurray  
President of Council

Attest: [Signature]  
Clerk of Council

Approved: [Signature], 2006

7-25-06 First Reading  
8-02-06 Second Reading  
Three reading rule suspended  
Passed

[Signature]  
David H. Madison, Mayor

HEATING / AIR CONDITIONING

PH: [614] - 274 - 2345

DATE: 7/18/06	# OF PAGES [ 1 ] OF [ 1 ]	JOB LOCATION:
TO: Bruce @ City of Bexley	FROM: KEVIN WEST	SAME
COMP: Bexley	COMP: AIRTRON	
PH: 205-3657	PH: [614] 274 - 2345	
FX: 235-3420	FX: [614] 276 - 5767	DATE: 7/18/06

THANK YOU FOR THE OPPORTUNITY TO QUOTE YOUR PROJECT:

Bruce,

Replacement of The 5 Ton Air handler and Air Conditioning System in  
 The Server room and Two Offices. We will be using a Small  
 Crane To Set this unit. Some Alterations to The plenum are necessary.  
 The unit will be placed on a Cabinet w/ Filter Rack

Standard 5 Ton Air Handler and 5 Ton 10 Seer Air Conditioner  
 Total \$ 4,770<sup>00</sup>

I quoted 10 Seer. Trane Had a Few. For 13 Seer we would have to  
 change the lineset (Increase size). This along with unit cost would  
 Increase the price by more than \$1,000<sup>00</sup>.

\*All Air Handlers are 220V. The existing is 110V. The new units  
 require a disconnect (included in above price). We will also need  
 to remove the 110 breaker & install a 220v breaker. The price for this  
 is also in the above prices. However IF there is not enough space in  
 the panel (IF piggybacks are required) additional charges would  
 be applied.

THE ABOVE PRICE INCLUDES: EQUIPMENT, MATERIAL, PERMITS, AND LABOR [ AT MERIT SHOP WAGES ]

CLARIFICATION:

1.] OUR PRICE IS BASED ON REGULAR WORKING HOURS, NORMAL JOBSITE CONDITIONS,  
 REASONABLE SCHEDULE AND REASONABLE ACCESS TO THE JOBSITE AND A CONTRACT  
 WITH CONDITIONS SIMILAR TO A.I.A. 401

2.] OUR PRICE ALSO DOES NOT INCLUDE ANY OF THE FOLLOWING:

- |                                                 |                                     |
|-------------------------------------------------|-------------------------------------|
| A.] HIGH VOLTAGE ELECTRIC I.E... 120, 240, 460V | F.] STRUCTURAL STEEL                |
| B.] DISCONNECTS, STARTERS, CONDUIT.             | G.] ASBESTOS ABATEMENT              |
| C.] ROOF SEALING AND FLASHING.                  | H.] CUT / CORING OF WALLS AND DECKS |
| D.] FLOOR DRAINS FOR CONDENSATE.                | I.] PAINTING                        |
| E.] GAS PIPING.                                 |                                     |

SIGNED BY:

