



## CITY OF BEXLEY TREE & PUBLIC GARDENS COMMISSION APPLICATION STAFF REVIEW

Project Name: Bexley Public Library  
 Project Address: 2411 E. Main Street  
 Reviewed by: Elena Andrews  
[elena@designspruce.com](mailto:elena@designspruce.com)  
 626-676-3330  
 Date: 9-12-18; Revised 9-14-18 v2

	Project Description	Completed	Incomplete	Missing	N/A
1a	Application	X			
1b	Project Description	X			
	<b>Research</b>				
2a	Significant examples	X			
	<b>Design Documentation Drawings</b>				
3a	Existing conditions photographs	X			
3b	Site plan or location plan	X			
3c	Schematic plan with north arrow and bar scale	X			
3d	Elevations, perspectives, isometrics, axonometrics or detailed model	X			
3e	Existing City trees indicated on plan	X			
3f	Proposed vegetation	X			
	<b>Recommended information</b>				
4a	Irrigation and maintenance plans	X			
4b	Hardscape layout and materials				X
4c	Lighting locations and specifications	X			
4d	Fixtures, furniture and equipment				X
4e	Accessories	X			
4f	Buildings				X
4g	Other				X

<b>Comments</b> <i>(Italicized comments are from previous review)</i>	
<b>3c</b>	<i>Please provide indicated scale of drawing and a bar scale.</i> Completed.
<b>3d</b>	<i>Please provide elevations of plantings along Main St, Euclaire Ave, and the alley.</i> Completed.
<b>3f</b>	<p><i>Plant counts do not match what is on the plan versus they key (boxwood, lilyturf, and Lilacs).</i> Corrected.</p> <p><i>If the Big Blue Liriope has been removed from the center island, is there any plant material going to be installed there?</i> Center island now includes Lilac trees, Liriope and two brick paths for pedestrian traffic.</p> <p><i>If the Karl Foerester Reed Grass is not going to be planted along the alleyway, what plant material will be installed to screen the parking lot?</i> Kar Foerester is still on plan so assuming it is part of the project.</p>
<b>4b</b>	<i>Confirm that there be a 6" concrete curb to protect the planting bed at the Northeast corner. Civil drawing shows one but the landscape drawing does not.</i> Included on Plan.
<b>4g</b>	<i>Proposed plant material is suitable to the site. I have concerns about the bed along the alley and the center median having no vegetation.</i> All requested changes have been addressed except for the submission of elevations.