

CITY OF BEXLEY TREE & PUBLIC GARDENS COMMISSION APPLICATION STAFF REVIEW

Project Name:Lyonsgate Landscaping along Stone WallProject Address:Clifton AveReviewed by:Elena Andrewselena@designspruce.com626-676-3330Date:10-29-18

	Project Description	Completed	Incomplete	Missing	N/A
1a	Application	Х			
1b	Project Description	Х			
	Research				
2 a	Significant examples				Х
	Design Documentation Drawings				
3a	Existing conditions photographs	Х			
3b	Site plan or location plan	Х			
3c	Schematic plan with north arrow and bar scale		Х		
3d	Elevations, perspectives, isometrics, axonometrics or detailed model	Х			
3e	Existing City trees indicated on plan				Х
3f	Proposed vegetation		Х		
	Recommended information				
4a	Irrigation and maintenance plans			Х	
4b	Hardscape layout and materials				Х
4c	Lighting locations and specifications				Х
4d	Fixtures, furniture and equipment				Х
4e	Accessories				Х
4f	Buildings				Х
4g	Other				Х

Comments (Italicized comments are from previous review)			
3с	Please provide a bar scale along with the indicated scale on the drawing. People may print this out at various paper sizes and the bar scale helps for reference.		
3f	Please indicated which trees are to be removed and which trees are existing. Is the blue spruce by the gate house being removed? The Acer platanoides 'Globosum' and Platanus x acerfolia 'Bloodgood' are both existing according to the images.		
	The plan legend shows all Hosta 'Patriots' while the renderings show a mix of various hosta. Which is correct? If it is the mix, please indicate Hosta Mix on plant legend.		
	It is understandable from a design perspective why there is a break in the bed in front of the gate in the stone wall to highlight the existing arborvitae. Why is there a second break nearer to the gate house? Perhaps consider another group of arborvitae to break up the bed line and give some height to the plantings?		